


CAB AHU SHUTDOWN

- NOTES
1. ALL INTERIOR WALLS, CEILINGS, FLOORS, DOORS, AND OTHER FINISHED CONSTRUCTION THAT ARE DAMAGED OR ALTERED BY THE CONTRACTOR SHALL BE RESTORED TO ORIGINAL CONDITION. PROVIDE NEW WALL PANELS/COUNTERTOPS WHERE EXISTING DEVICES/EQUIPMENT HAVE BEEN REMOVED. COLOR AND MATERIAL SHALL BE SIMILAR TO EXISTING AND SHALL BE APPROVED BY THE RESIDENT ENGINEER PRIOR TO INSTALLATION.
 2. SEE SHEET G03 FOR GENERAL NOTES AND LEGENDS.
 3. REPLACE THE ENTIRE EXISTING FIRE ALARM SYSTEM, INCLUDING INITIATION DEVICES, NOTIFICATION APPLIANCES, CONTROL RELAYS AND WIRING WITH A COMPLETE NEW FIRE ALARM SYSTEM.
 4. SMOKE DETECTORS SHALL BE MOUNTED IN THE CENTER OF TILE TO THE MAXIMUM EXTENT PRACTICAL. SUPPORT JUNCTION BOXES/ DETECTORS WITH T-BARS.
 5. SMOKE DETECTORS SHALL BE LOCATED A MINIMUM OF 3 FEET FROM SUPPLY AND RETURN AIR DIFFUSERS. WHERE THIS IS NOT POSSIBLE, INSTALL AIRFLOW DEFLECTORS ON SUPPLY AIR DIFFUSERS.
 6. INSTALL ALL ADDRESSABLE RELAYS AND ADDRESSABLE MONITOR MODULES WITHIN 3 FEET OF THE CONTACT POINTS THEY CONTROL OR MONITOR.
 7. LOCATIONS OF SMOKE AND HEAT DETECTORS ON DRAWINGS ARE APPROXIMATE ONLY. COORDINATE THE INSTALLATION OF SMOKE AND HEAT DETECTORS WITH EXISTING LIGHTING AND HVAC EQUIPMENT.
 8. ALL NEW DETECTORS SHALL BE MOUNTED BELOW THE FINISHED CEILING OR AT THE STRUCTURE IN AREAS WITHOUT A FINISHED CEILING, UNLESS OTHERWISE SPECIFICALLY NOTED ON THE DRAWINGS.
 9. COORDINATE ALL DEVICE LOCATIONS IN THE CAB WITH THE RESIDENT ENGINEER.

1 CAB FLOOR PLAN - FIRE ALARM
F05 SCALE: 1/2" = 1'-0"



GEORGIA REGISTERED PROFESSIONAL ENGINEER
NO. 024337
DOUGLAS W. FISHER

HARTRAMPF

7000 CENTRAL PARKWAY, SUITE 1475
ATLANTA, GEORGIA 30328

REV.	LTR.	DATE	DESCRIPTION	CHECKED	APPROVED
DEPARTMENT OF TRANSPORTATION FEDERAL AVIATION ADMINISTRATION SOUTHERN REGION ATLANTA, GEORGIA 30320					
AIRPORT TRAFFIC CONTROL TOWER (ATCT) FIRE AND LIFE SAFETY MODIFICATIONS CAB FLOOR PLAN FIRE ALARM SYSTEM					
JACKSON		HAWKINS FIELD		MS	
REVIEWED BY	SUBMITTED BY		APPROVED BY		
DESIGNED BY	ISSUED BY		DATE		
MAS	ATLANTA NAS		12-18-2006		
DRAWN BY	IMPLEMENTATION		DRAWING NO.		
HJM	CENTER		SO-D-103765-F05		
CHECKED BY			REV. LTR.		
DWF					